



WALL / DOOR TO BE SHIFTED TO MAKE THE LIFT LOBBY ENCLOSED

cutout missing in rcc wall. architect to check.

plant room wall missing

cutout required. not marked by architect in drawing.

cutout required for lift lobby pressurization.

ventilation cutout location interference with retaining wall. architect to check.

For Sparsh Builders Pvt. Ltd.
Authorised Signatory

SIGNATURE OF OWNER SIGNATURE OF ARCHITECT

PROJECT TITLE:
PROPOSED COMMERCIAL AT COMMERCIAL PLOT NO - C7,
CROSSINGS REPUBLIK, DUNDAHERA, GHAZIABAD

OWNER:
M/S SPARSH BUILDERS PVT. LTD.

Architect :
M/s Anuj Agarwal Architects
ARCHITECTS, ENGINEERS, INTERIOR DESIGNERS & VASTU CONSULTANTS
Office-A-244, Behind Angel Mega Mall, Kaushambi, Ghaziabad
Ph.: 0120-4165716, 4563716, 4157506
Email: arch.anujagarwal@gmail.com

Services Consultant :
Consummate Engineering Services (P) Ltd.
Noida Office : B - 67, Sector - 67, Noida - 201 301
Tel : (0120)6943500 (23 Lines)
Lko. Office : R 006, Rohtas Plumeria, Gomti Nagar, Lucknow
e mail : mail@cespl.in, website : www.cespl.in

DRAWING TITLE:
SECOND BASEMENT LAYOUT
UGT & DG LAYOUT

Drawing Released For :
APPROVAL SUBMISSION
ADVANCE COPY CONSTRUCTION

Drg. No : COMM. / BAS.-2 / MEP-01

Scale : N.T.S. Drawn by :

Date: Jan. 2022 Designed by: R.k

Ckd By:

Rev. No.	Date	Revision

